



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-6330AT2061

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Hans Sasserath GmbH & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Distributor <i>Vertreiber</i>	Hans Sasserath GmbH & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Product Category <i>Produktart</i>	valves for drinking water: cold water pressure reducing valve (6330)
Product Description <i>Produktbezeichnung</i>	cold water pressure reducing valve
Model <i>Modell</i>	314.1; 314.S; 314.N; 4315; 315; 315 AB; 315.1; 315.2
Test Reports <i>Prüfberichte</i>	laboratory control test: DM 004/17 from 02.10.2017 (TZW) supplement test: DM 001/18 from 06.08.2018 (TZW) supplement test: DM 002/14 from 03.08.2015 (TZW) type testing: DM 006/10 - DM 011/10 from 03.02.2011 (TZW) UBA-Guideline: K-273960-16-Bs/st from 08.08.2016 (WHY)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 1567 (01.01.2000) UBA METALLE (26.03.2018) UBA KTW (07.03.2016) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	21.12.2023 / 18-0523-WNV

25.10.2018 Wg A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
314.1; 314.S; 314.N; 4315; 315; 315 AB; 315.1; 315.2	noise emission class: I / II pressure rating: PN 16 nominal diameter: DN 15	type 314.N (noise class: II)
4315; 315; 315 AB; 315.1; 315.2	noise emission class: I / II pressure rating: PN 16 nominal diameter: DN 20	type 315.1 (noise class: II)
4315; 315; 315 AB; 315.2	noise emission class: I pressure rating: PN 16 nominal diameter: DN 25	
4315; 315; 315 AB; 315.2	noise emission class: I pressure rating: PN 16 nominal diameter: DN 32	
4315; 315; 315 AB; 315.2	pressure rating: PN 16 nominal diameter: DN 40	
4315; 315; 315 AB; 315.2	pressure rating: PN 16 nominal diameter: DN 50	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
314.1; 314.S; 314.N; 315.1	inlet side: external thread, outlet side: connection adapter only in combination with a drinking water safety unit
315; 315 AB; 4315; 315.2	inlet and outlet side: threaded connection with external thread

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

ABP for types:

314.1: P-IX 7636/I (noise class I: DN 15)

314.S: P-IX 16708/I (noise class I: DN 15)

314.N; P-IX 16867/II (noise class II; DN 15)

315 and 315 AB: P-IX 7635/I (noise class I: DN 15, DN 20, DN 25)

315 and 315 AB: P-IX 7729/I (noise class I: DN 32)

315.1: P-IX 16742/I (noise class I: DN 15)

315.2: P-IX 6902/I (noise class I: DN 15, DN 20, DN 25, DN 32)

4315: P-IX 7905/I (noise class I: DN 15, DN 20, DN 25, DN 32)

Oras no	SYR type
433020	315 DN20
433025	315 DN25
433032	315 DN32
433040	315 DN40
433050	315 DN50